

Orica Kooragang Island Monitoring Point 30

EPA Licence No: 828
 Licensee Name: ORICA AUSTRALIA PTY LTD
 Licensee Address: 15 Greenleaf Rd, KOORAGANG NSW 2304

Monthly Summary

Sampling/Monitoring Period	Monitoring Point	Location of Monitoring Point	Date Published	Monitoring Frequency Required by Licence	Units of Measure	No. of Times measured during month	Min. Value	Mean Value	Max Value	EPL Limit
Jan-15	30	Main Transpiration Area	21/05/15	Flow	kL/Day	31	5.8	9.8	15.5	20
Feb-15	30	Main Transpiration Area	21/05/15	Flow	kL/Day	28	5.7	9.0	14.0	20
Mar-15	30	Main Transpiration Area	21/05/15	Flow	kL/Day	31	4.4	6.8	11.9	20
Apr-15	30	Main Transpiration Area	21/05/15	Flow	kL/Day	30	6.4	22.2	86.8	20
May-15	30	Main Transpiration Area	1/06/15	Flow	kL/Day	31	20.5	20.5	47.3	20
Jun-15	30	Main Transpiration Area	6/07/15	Flow	kL/Day	30	14.6	21.2	40.4	20
Jul-15	30	Main Transpiration Area	7/08/15	Flow	kL/Day	31	12.4	19.1	29.0	20
Aug-15	30	Main Transpiration Area	2/09/15	Flow	kL/Day	31	8.6	12.0	16.8	20
Sep-15	30	Main Transpiration Area	1/10/15	Flow	kL/Day	30	9.4	13.4	17.5	20
Oct-15	30	Main Transpiration Area	9/11/15	Flow	kL/Day	31	11.1	16.2	44.5	20
Nov-15	30	Main Transpiration Area	2/12/15	Flow	kL/Day	30	8	16.6	13.2	20
Dec-15	30	Main Transpiration Area	4/01/16	Flow	kL/Day	31	7.4	11.7	15.0	20
Jan-16	30	Main Transpiration Area	11/02/16	Flow	kL/Day	31	9.1	10.5	100.5	20
Feb-16	30	Main Transpiration Area	4/03/16	Flow	kL/Day	29	16.3	22.4	30.2	20
Mar-16	30	Main Transpiration Area	8/04/16	Flow	kL/Day	31	9.8	15.7	23.1	20
Apr-16	30	Main Transpiration Area	4/05/16	Flow	kL/Day	30	9.4	12.7	17.7	20
May-16	30	Main Transpiration Area	6/06/16	Flow	kL/Day	31	7.0	10.7	15.4	20
Jun-16	30	Main Transpiration Area	4/07/16	Flow	kL/Day	30	10.0	18.6	24.5	20
Jul-16	30	Main Transpiration Area	5/08/16	Flow	kL/Day	31	11.7	15.6	22.6	20
Aug-16	30	Main Transpiration Area	2/09/16	Flow	kL/Day	31	11.0	15.6	30.9	20
Sep-16	30	Main Transpiration Area	4/10/16	Flow	kL/Day	30	0	12.6	21.5	20
Oct-16	30	Main Transpiration Area	4/11/16	Flow	kL/Day	31	3.3	5.7	9.7	20
Nov-16	30	Main Transpiration Area	2/12/16	Flow	kL/Day	30	0.0	5.3	11.3	20
Dec-16	30	Main Transpiration Area	5/01/17	Flow	kL/Day	31	2.1	6.5	4.1	20
Jan-17	30	Main Transpiration Area	6/02/17	Flow	kL/Day	31	2.2	6.0	4.0	20
Feb-17	30	Main Transpiration Area	6/03/17	Flow	kL/Day	28	2.6	5.3	10.9	20
Mar-17	30	Main Transpiration Area	7/04/17	Flow	kL/Day	31	4.3	8.9	13.0	20
Apr-17	30	Main Transpiration Area	1/05/17	Flow	kL/Day	30	8.0	8.9	11.5	20
May-17	30	Main Transpiration Area	2/06/17	Flow	kL/Day	31	7.6	8.9	9.9	20